



Sweillem Vitrified Clay Pipes CO.

21

EN 295-1:2013

Vitrified Clay Pipes for drains and sewers buried in ground
DN 300 – 2.0 – FN 72 - C

Reaction to fire	Class A1
Crushing strength (F_N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	Pass
- Squareness of ends	Pass
- Straightness	Pass
- Continuity of invert	Pass
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	28 MPa
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid





Sweillem Vitrified Clay Pipes CO.

21

EN 295-1:2013

Vitrified Clay connector for drains and sewers buried in ground

DN 300 – 0.75 GZ FN 72 – C

DN 300 – 0.75 GA FN 72 - C

Reaction to fire	Class A1
Crushing strength (F_N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	Pass
- Squareness of ends	Pass
- Angle of curvature	Pass
- Continuity of invert	Pass
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid





Sweillem Vitrified Clay Pipes CO.

21

EN 295-1:2013

Vitrified Clay connector for drains and sewers buried in ground
DN 300 – 0.25 GE FN 72 - C

Reaction to fire	Class A1
Crushing strength (F_N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	Pass
- Squareness of ends	Pass
- Straightness	Pass
- Continuity of invert	Pass
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid





Sweillem Vitrified Clay Pipes CO.

21

EN 295-1:2013

Vitrified Clay connector for drains and sewers buried in ground
DN 300 – GM FN 72 - C

Reaction to fire	Class A1
Crushing strength (F_N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	NPD
- Length	NPD
- Squareness of ends	NPD
- Straightness	NPD
- Continuity of invert	NPD
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	NPD
- Airtightness	NPD
Durability of watertightness against:	
- Chemical and physical resistance to effluent	NPD
- Thermal cycling stability	NPD
- Long term thermal stability	NPD
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid





Sweillem Vitrified Clay Pipes CO.
21

EN 295-1:2013

Vitrified Clay bends for drains and sewers buried in ground

DN 300 –FN 72 – C– 15°

DN 300 –FN 72 – C– 30°

DN 300 –FN 72 – C– 45°

DN 300 –FN 72 – C– 90°

Reaction to fire	Class A1
Crushing strength (F _N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	NPD
- Squareness of ends	NPD
- Straightness	NPD
- Continuity of invert	NPD
- Angle of curvature	Pass
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid





Sweillem Vitrified Clay Pipes CO.
21

EN 295-1:2013

Vitrified Clay Junctions for drains and sewers buried in ground

DN 300-150 – 0.5 FN 72-34 – C/F 45°

DN 300-150 – 0.5 FN 72-34 – C/F 90°

DN 300-200 – 0.6 FN 72-40 – C/F 45°

DN 300-200 – 0.6 FN 72-40 – C/F 90°

DN 300-200 – 0.6 FN 72-40 – C/C 45°

DN 300-200 – 0.6 FN 72-40 – C/C 90°

Reaction to fire	Class A1
Crushing strength (F_N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	Pass
- Squareness of ends	Pass
- Straightness	Pass
- Continuity of invert	Pass
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid





Sweillem Vitrified Clay Pipes CO.
21

EN 295-1:2013

Vitrified Clay Repair Junctions for drains and sewers buried in ground

DN 300-150 – 0.5 FN 72-34 – R/F 45°

DN 300-150 – 0.5 FN 72-34 – R/F 90°

DN 300-200 – 0.6 FN 72-40 – R/F 45°

DN 300-200 – 0.6 FN 72-40 – R/F 90°

DN 300-200 – 0.6 FN 72-40 – R/C 45°

DN 300-200 – 0.6 FN 72-40 – R/C 90°

Reaction to fire	Class A1
Crushing strength (F _N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	Pass
- Squareness of ends	Pass
- Straightness	Pass
- Continuity of invert	Pass
- Joint inter-changeability	R
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid





Sweillem Vitrified Clay Pipes CO.

21

EN 295-1:2013

Vitrified Clay stopper for drains and sewers buried in ground
DN 300 – FN 72 - C

Reaction to fire	Class A1
Crushing strength (F _N)	72 KN/m
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	Pass
- Squareness of ends	Pass
- Straightness	Pass
- Continuity of invert	Pass
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid



CE

Sweillem Vitrified Clay Pipes CO.

21

EN 295-1:2013

Vitrified Clay Reducer for drains and sewers buried in ground
 DN 300-250- FN 72-40 C/C

Reaction to fire	Class A1
Longitudinal bending strength:	
- Bending moment resistance (BMR)	NPD
Dimensional tolerances, concerning:	
- Internal diameter	Pass
- Length	NPD
- Squareness of ends	Pass
- Straightness	NPD
- Continuity of invert	NPD
- Joint inter-changeability	System C
Watertightness (gas and liquid) and permeability as:	
- Watertightness	Pass
- Airtightness	Pass
Durability of watertightness against:	
- Chemical and physical resistance to effluent	Pass
- Thermal cycling stability	Pass
- Long term thermal stability	Pass
Durability of crushing strength and longitudinal bending strength, against:	
- Chemical resistance	< 0.15
- Resistance against high pressure water jetting	NPD
- Water absorption	< 6.0 % Wt.

HEAD OF QUALITY CONTROL
Ahmed Mohamed Wahid

